




How to gradually acclimate MELiSSA's nitrification compartment to urine mixed with VFA-rich anaerobic digestion (C1) effluent

Koen Rummens, Katrien Thys, Ilse Smets



Problem statement & Space relation



2



00 0


anaerobic membrane bioreactor (ALSS/C1)

black water/ kitchen waste

acids

(VFA)

 CO_2



nitrification reactor (NSS/C3) urine organic acids NH_4^+ (VFA) NO₃- CO_2

Solution = BWT Breadboard

general goals


- digestion of waste (water) produced by 1/4th of person per day
- direct coupling of anaerobic membrane bioreactor to nitrification reactor
- anaerobic membrane bioreactor goals
 - treatment of waste 1/4th person = 2.5 L/day & 48 g DM/day
 - steady state approximating performance of previous run at MPP
 - carbon balance & conversion efficiency

nitrification reactor goals

- treatment of waste 1/4th person = 350-400 mL urine/day & 3 g N/day
- coupling: organic effluent + urine (4:1 composition) to nitrification reactor
- balance of heterotrophic and nitrifying bacteria (mixed non-axenic cultures!)




Activity description **NITRIFICATION REACTOR**








Packed bed configuration






Packed bed configuration






Packed bed configuration






Good oxygen recovery

- Fed 12 times a day (once every 2 hours)
- Fast recovery
- Small drop in oxygen concentration



Bad oxygen recovery

- Fed 6 times a day (once every 4 hours)
- Slow recovery
- Large drop in oxygen concentration






Fluidized bed configuration




- K1 AnoxKaldnes carriers (50 % filling ratio)
- 3 L carriers + 7.5 L reactor fluid
- Surface area = 2.07 m² Protected area = 1.51 m²








Fluidized bed configuration



11



Fluidized bed configuration




12




Lower loading (day 218)

- 1883 mg N/d
- 7258 mg COD/d (< 2668 mg VFA/d)
- influent flow rate 1224 mL/d



± Highest loading (day 270)

- 2734 mg N/d
- 11215 mg COD/d (< 4000 mg VFA/d)
- influent flow rate 1818 mL/d





Conclusions



- fixed bed operations can be replaced by e.g. **fluidized bed**
- nitrogen overload inhibition can be avoided by gradually increasing N load (decision tree is available)
- a feed with 2.85 g N/day and a C/N ratio of 4 is minimally feasible
- a very careful **control of the pH** (above 7!!) is crucial
- temperature above 20 degrees is a must
- a lot of **excess biomass** is produced





Collaboration between

KU Leuven KU LEUVEN

- Chemical Engineering Department (Bio)Chemical Reactor Technology & Safety Division [Ilse Smets (coordinator), Kristel Bernaerts, Koen Rummens]
- Earth and Environmental Sciences [Dirk Springael, Jaak Ryckeboer]
- UGent

•

- cmet [Korneel Rabaey, Peter Clauwaert, Amanda Luther]
- MPP, Universitat Autonoma de Barcelona (UAB)
- Consulting partners
 - Université Blaise Pascal`-Polytech (UBP, Clermont-Ferrand, C3 expertise)
 - Sherpa (process control and data archiving)
 - VITO (C1 expertise, waste preparation unit)





Universitat Autònoma de Barcelona



THANK YOU.

Koen Rummens KU Leuven – CIT – CREaS koen.rummens@kuleuven.be

www.**melissafoundation**.org



PARTNERS

